

Martin Black - update

From: John Reed
To: Martin Black
Date: 3/11/2008 5:18 PM
Subject: update

Marty,

Based on conversations with Jack and the information contained in Dan's memo there is not a reason to close Tavern on the Island down at this point from a fire safety perspective. They are still classified as a Mercantile Occupancy and fire sprinklers are not required under that classification based on the current criteria. If the business changes to Assembly the Building Code would require fire sprinklers based on the occupant load. The Fire Code does not require fire sprinklers under the current code. The anticipated code changes in October may change that requirement. The current occupant load is being calculated by Randy and that information will be available tomorrow. The occupant load will be based on a Mercantile occupancy which allows 1 person per 30 Sq. Ft. I will get with you tomorrow before the staff meeting. My daughter has an awards banquet tonight so I am going to take off. I'll see you in the morning. Hopefully, you will be finished shortly!

John

John Reed
Fire Chief
City of Venice Fire Department
200 Grove St. N.
Venice, FL 34285
Phone: 941-480-3030
Facsimile; 941-480-3224
E-MAIL: jreed@ci.venice.fl.us

Serving the City of Venice with PRIDE
Productive - Responsible - Innovative - Dedicated - Ethical

Any electronic data sent or received through this e-mail is public record governed by the State of Florida Public records Law